



## PRECAST CONCRETE SAMPLING MANHOLE

4'-0" x 4'-0" square x 3'-9" deep, ID  
 6" walls, 6" base & 6" top

CONCRETE 4,000 PSI  
 Joint(s) sealed with butyl rope form & mortar

Reinforcing:  
 Walls - # 4 rebar, 10" c/c e/w  
 Top - # 4 rebar, 8" c/c e/w  
 Base - # 4 rebar, 10" c/c e/w  
 REBAR GRADE 60

Interior coatings: NONE  
 Exterior coatings: Two coats black bituminous tar

**J.F. Gillespie, Inc.**  
**2547 Brunetta Drive**  
**Vineland, NJ 08360**  
**phone: 856-692-2233**  
**fax: 856-692-5457**  
**www.jfgillespieinc.com**